

LEITRIM COUNTY COUNCIL

GRAVE-SPACE DEVELOPMENT

GENERAL REQUIREMENTS

1. Headstones shall not exceed 1.2 metres in height (measured from finished ground level).
2. The excess material in the grave mound shall be removed prior to space development and deposited in the area designated for that purpose by the Local Authority.
3. Top soil shall be removed over the entire plot area to a depth of 150mm and deposited in the area in 2 above.
4. Kerb foundations shall be in 1:10 (cement:aggregate) concrete 150mm wider than the kerb width and not visible above ground level.
5. Kerb surrounds to adjoining plots shall abutt without intervening gaps.
6. The kerbed area shall be finished in a sand/cement mix 75mm thick and finished in white limestone chippings.
7. Concrete shall not be mixed on site or on any part of public property.
8. All excess material arising shall be removed from site on the completion of works.
9. The Local Authority caretaker shall be advised of work commencement and completion.